



# 中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2019010307179442

纸 号: 2283583

### 参数:

Uimp: 8kV; Ui: 800V; Ue: AC230V  
 (2P), AC400V (3P, 3P+N, 4P); In: 16A, 20A, 25A, 32A, 40A, 50A,  
 63A, 80A, 100A, 125A; 过电流脱扣器类型: 热磁式, 单磁式; L 型; Ics:  
 25kA; Icu: 35kA; M 型; Ics: 35kA; Icu: 50kA; IΔn: 30mA(仅适用于  
 非延时); 50mA, 100mA, 200mA, 300mA, 500mA(任选三档分档可调)/AC  
 型; 剩余电流脱扣器类型: 电子式; IΔn: 25%Ics; 使用类别: A 类; 极数:  
 2P(两个保护极, 适用于隔离用), 3P(三个保护极, 适用于隔离用), 3P+N(三  
 个保护极, 带不可开断中性线, 不适用于隔离用), 4P(三个保护极, N 极可  
 开断, 适用于隔离用); 适用频率: 50/60Hz; 辅助触头: 2NO2NC; Ith: 3A;  
 AC-15 Ue: 400V; Ie: 0.4A; DC-13 Ue: 220V; Ie: 0.15A

### 型号的解释:

BHE M 3 L - 125 □ / □ □ □

(1) (2) (3) (4) (5) (6) (7) (8) (9)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计序号
- (4) 带剩余电流保护
- (5) 壳架等级额定电流 (A)
- (6) 额定极限短路分断能力级别(分为 L、M 两种)
- (7) 极数 (2: 2P, 3: 3P, 4: 3P+N, 4P)
- (8) 脱扣器方式及附件代号(见表 1)
- (9) 中性线代号 (A: 中性线直通; B: 中性线可分断)

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



## 中国质量认证中心



# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2019010307179442

纸 号: 2283583

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	辅助触头	分励脱扣器辅助触头
过流脱扣器方式	代 号			
复式脱扣器	300	310	320	340
瞬时脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



## 中国质量认证中心



# 中国国家强制性产品认证证书

证书编号: 2019010307179442

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内六楼)

产品名称和系列、规格、型号

剩余电流动作断路器

BHEM3L-125L、BHEM3L-125M; 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月07日 有效期至: 2024年05月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任:

陆楠



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307179442

## NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

## PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Circuit-Breaker  
BHEM3L-125L, BHEM3L-125M; See the Appendix for type explanation

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up  
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书






附 录

第 1 页 共 1 页

证书编号: 2019010307179446

纸 号: 2283584

型号的解读:

 M 3 L - 250  /     
 (1) (2) (3) (4) (5) (6) (7) (8) (9)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计序号
- (4) 带剩余电流保护
- (5) 壳架等级额定电流 (A)
- (6) 额定极限短路分断能力级别(分为 L、M 两种)
- (7) 极数 (2: 2P, 3: 3P, 4: 3P+N, 4P)
- (8) 脱扣器方式及附件代号(见表 1)
- (9) 中性线代号 (A: 中性线直通; B: 中性线可分断)

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	辅助触头	分励脱扣器辅助触头
过流脱扣器方式	代 号			
复式脱扣器	300	310	320	340
磁热脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



## 中国质量认证中心



# 中国国家强制性产品认证证书

证书编号: 2019010307179446

## 委托人名称、地址

浙江北华电气有限公司  
浙江省温州市乐清市乐清经济开发区纬五路187号(浙江远点电子股份有限公司内)

## 生产者(制造商)名称、地址

浙江北华电气有限公司  
浙江省温州市乐清市乐清经济开发区纬五路187号(浙江远点电子股份有限公司内)

## 生产企业名称、地址

浙江北华电气有限公司  
浙江省温州市乐清市乐清经济开发区纬五路187号(浙江远点电子股份有限公司内六楼)

## 产品名称和系列、规格、型号

剩余电流动作断路器

BHEM3L-250L, BHEM3L-250M Uimp: 8kV; Ui: 800V; Ue: AC230V (2P), AC400V (3P, 3P+N, 4P);  
In: 100A, 125A, 140A, 160A, 180A, 200A, 225A, 250A; 过电流脱扣器类型: 热磁式, 电磁式;  
L型: Ics: 25kA; Icu: 35kA; M型: Ics: 35kA; Icu: 50kA; Idn: 50mA, 100mA, 200mA, 300mA,  
500mA(任选二档分档可调)AC型; 剩余电流脱扣器类型: 电子式; Idn: 25%Icn; 使用类别: A类;  
极数: 2P(两个保护极, 适用于隔离用), 3P(三个保护极, 适用于隔离用), 3P+N(三个保护极,  
带不可开断中性线, 不适用于隔离用), 4P(三个保护极, N极可开断, 适用于隔离用); 适用频率:  
50/60Hz; 精制触点: 2NC2NC; In: 3A; AC-15 Ue: 400V; In: 0.4A; DC-13Ue: 220V; In: 0.15A;  
型号解释见附件

## 产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,  
特发此证。

发证日期: 2019年05月07日 有效期至: 2024年05月07日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任:

陆楠



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307179446

## NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 5)

## PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Circuit-Breaker

BHEM3L-250L, BHEM3L-250M Ump; 8kV; U<sub>i</sub>: 800V; U<sub>e</sub>: AC230V (2P), AC400V (3P, 3P+N, 4P); In: 103A, 125A, 143A, 160A, 180A, 200A, 225A, 250A; Over-current Release: Thermal Magnetic, Single magnetic type; L型; Ics: 25kA; Icu: 35kA; M型; Ics: 35kA; Icu: 50kA; IΔn: 50mA, 100mA, 200mA, 300mA, 500mA(任意三档分档可调)AC型; Electronic Residual Current Tripping Unit; IΔn: 25%Icn; Utilization Category: A型; Poles: 2P(With two protective poles, Suitable for insulation), 3P(With three protective poles, Suitable for insulation), 3P+N(With three protective poles, Uninterrupted neutral, Not-suitable for insulation), 4P(With three protective poles,Switched neutral pole, Suitable for insulation); 适用频率: 50/60Hz; Attached Auxiliary Contacts: 2NO/2NC; Ith: 3A; AC-15 Ue: 400V, Ie: 0.4A; DC-13Ue: 220V, Ie: 0.15A

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02-2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: [www.cqcc.com.cn](http://www.cqcc.com.cn)



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2019010307166798

纸 号: 2230473

BHEM3L-400L、BHEM3L-400M;

Ui: 800V; Uimp: 8kV;

Ue: AC400V;

In: 225A, 250A, 315A, 350A, 400A;

过电流脱扣器类型: 热磁式;

L 型: Ics: 35kA, Icu: 50kA;

M 型: Ics: 50kA, Icu: 65kA;

IΔn: 100mA/300mA/500mA(可调)/AC 型;

剩余电流脱扣器类型: 电子式; IΔm: 25%Icu;

使用类别: A 类;

极数: 3P (适用于隔离用), 3P+N(三个保护极, 带不可开断中性线, 不适用于隔离用),

4P(三个保护极, N 极可开断, 适用于隔离用);

辅助触头: 2NO2NC ; Ith: 3A;

AO-15 Ue: 400V; Ie: 0.4A;

DO-13 Ue: 220V; Ie: 0.15A.

注: 此附录与证书同时使用时有效。



主 任: 陆 楠



## 中国质量认证中心





# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2019010307166798

纸 号: 2230473

型号的解读:

BBE M 3 L - 400 □ / □ □ □  
 (1) (2) (3) (4) (5) (6) (7) (8) (9)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计序号
- (4) 带剩余电流保护
- (5) 壳架等级额定电流 (A)
- (6) 额定极限短路分断能力级别(分为 L、M 两种)
- (7) 极数 (3: 3P, 4: 3P+N, 4P)
- (8) 脱扣器方式及附件代号(见表 1)
- (9) 中性线代号 (A: 中性线直通; B: 中性线可分断; 3P 产品不标)

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	一组辅助触头	分励脱扣器辅助触头
过流脱扣器方式	代 号			
复式脱扣器	300	310	320	340
瞬时脱扣器	300	310	320	340

注: 此附录与证书同时使用时有效。



主 任:

陆梅



## 中国质量认证中心



# 中国国家强制性产品认证证书

证书编号: 2019010307166798

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江过点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江过点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江过点电子股份有限公司内六楼)

产品名称和系列、规格、型号

剩余电流动作断路器

BHEM3L-400L、BHEM3L-400M; 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年03月26日 有效期至: 2024年03月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任:

陆楠



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307166798

## NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

## PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Circuit-Breaker  
BHEM3L-400L, BHEM3L-400M, See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO.CNCA-C03-02-2014).

Valid from: Mar.26,2019

Valid until: Mar.26,2024

The validity of the certificate is subject to positive result of the regular follow up  
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2019010307179339

纸 号: 2283582

### 参数:

Uimp: 8kV; Ui: 800V; Ue: AC400V; In: 400A, 500A, 630A, 700A, 800A; 过电流脱扣器类型: 热磁式、电磁式; L 型: Ics: 35kA; Icu: 50kA; M 型: Ics: 50kA; Icu: 70kA; IΔn: 300mA, 500mA, 1000mA(可调)/AC 型; 剩余电流脱扣器类型: 电子式; IΔm: 25%Icu; 使用类别: A 类: 极数: 3P (三个保护极, 适用于隔离用), 3P+N(三个保护极, 带不可开断中性线, 不适用于隔离用); 4P(三个保护极, N 极可开断, 适用于隔离用); 适用频率: 50/60Hz; 辅助触头: 2NO2NC; Ith: 3A; AC-15 Ue: 400V; Ie: 0.4A; DC-13 Ue: 220V; Ie: 0.15A.

### 型号的解釋:

BHE M 3 L - 800  /

(1) (2) (3) (4) (5) (6) (7) (8) (9)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计序号
- (4) 带剩余电流保护
- (5) 壳架等级额定电流 (A)
- (6) 额定极限短路分断能力级别(分为 L、M 两种)
- (7) 极数 (3: 3P, 4: 3P+N, 4P)
- (8) 脱扣器方式及附件代号(见表 1)
- (9) 中性线代号 (A: 中性线直通; B: 中性线可分断)

注: 此附录与证书同时使用时有效。



主 任: 陆楠



## 中国质量认证中心



# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2019010307179339

纸 号: 2283582

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	辅助触头	分励脱扣器辅助触头
过流脱扣器方式	代 号			
复式脱扣器	300	310	320	340
瞬时脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



## 中国质量认证中心



# 中国国家强制性产品认证证书

证书编号: 2019010307179339

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内六楼)

产品名称和系列、规格、型号

剩余电流动作断路器

BHEM3L-800L、BHEM3L-800M; 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月07日 有效期至: 2024年05月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任:

陆楠



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307179339

## NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C.(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C.(In the JD Longwayflex Co., Ltd)

## NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd  
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang  
Province,P.R.C.(In the JD Longwayflex Co., Ltd Floor 5)

## PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Circuit-Breaker  
BHEM3L-80CL、BHEM3L-800M; See the Appendix for type explanation

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO.CNCA-C03-02-2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up  
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE