



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2019010307170241

纸 号: 2260218

BHEW3-2500, BHEW3-2500/4;

U_i: 1250V; U_{imp}: 12kV;

U_e: AC400V/AC500V/AC690V/AC800V/AC1140V;

I_n: 630A, 800A, 1000A, 1250A, 1600A, 2000A, 2500A;

过电流脱扣器类型: 电子式;

AC400V; I_{cs}: 80kA, I_{cw}: 85kA, I_{cw}: 80kA/1s;

AC500V/690V; I_{cs}: 65kA, I_{cw}: 65kA, I_{cw}: 65kA/1s;

AC800V/AC1140V; I_{cs}: 50kA, I_{cw}: 50 kA, I_{cw}: 50kA/1s;

使用类别: B;

极数: 3P、4P (均为保护极, 适用于隔离用);

频率适用于: 50/60Hz;

配用的辅助触头: 4NO4NC, I_{th}: 6A;

AC-15: U_e: AC230V/I_e: 1.5A, U_e: AC400V/I_e: 0.9A;

DC-13: U_e: DC220V/I_e: 0.27A, U_e: DC110V/I_e: 0.55A.

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307170241

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内六楼)

产品名称和系列、规格、型号

万能式断路器

BHEW3-2500、BHEW3-2500/4; 参数详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年04月08日 有效期至: 2024年04月08日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307170241

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Conventional Circuit-Breaker
BHEW3-2500, BHEW3-2500I4; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Apr.08,2019

Valid until: Apr.08,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2019010307169843

纸 号: 2260217

BHEW3-4000, BHEW3-4000/4;

U_i: 1250V; U_{imp}: 12kV;

U_e: AC400V/AC500V/AC690V/AC800V/AC1140V;

I_n: 2500A, 2900A, 3200A, 3600A, 4000A;

过电流脱扣器类型: 电子式;

AC400V; I_{cs}: 100kA, I_{cu}: 100kA, I_{cw}: 100kA/1s;

AC500V/690V; I_{cs}: 70kA, I_{cu}: 70kA, I_{cw}: 70kA/1s;

AC800V/AC1140V; I_{cs}: 50kA, I_{cu}: 50kA, I_{cw}: 50kA/1s;

使用类别: B;

极数: 3P、4P (均为保护极, 适用于隔离用);

频率适用于: 50/60Hz;

配用的辅助触头: 4NO4NC, I_{th}: 6A;

AC-15: U_e: AC230V/I_e: 1.5A, U_e: AC400V/I_e: 0.9A;

DC-13: U_e: DC220V/I_e: 0.27A, U_e: DC110V/I_e: 0.55A

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307169843

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内六楼)

产品名称和系列、规格、型号

万能式断路器

BHEW3-4000、BHEW3-4000/4; 参数详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特此认证。

发证日期: 2019年04月08日 有效期至: 2024年04月08日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307169843

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C.(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C.(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C.(in the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Conventional Circuit-Breaker
BHEW3-4000, BHEW3-4000/4; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Apr.08,2019

Valid until: Apr.08,2024

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE